

BRIAN SANDOVAL
Governor

STATE OF NEVADA

STEVE GEORGE
Administrator

BRUCE BRESLOW
Director



JAN ROSENBERG,
CSP, CSHM, CPCU, ARM, CFM
Deputy Administrator

RANDY JEWETT
Chief Administrative Officer

GARY SCHULTZ
Safety Manager

DEPARTMENT OF BUSINESS AND INDUSTRY
DIVISION OF INDUSTRIAL RELATIONS
MECHANICAL COMPLIANCE SECTION
4600 Kietzke Lane, Suite F-151
Reno, Nevada 89502


MEMORANDUM


DATE: 9/3/15
TO: All Authorized Inspection Agencies and Elevator Service Companies
FROM: Randy Jewett CAO Mechanical Compliance Section
SUBJECT: Fire Service Testing of Elevators

Fire Service Testing of Elevators must follow A17.1-2013, section 8.6.4.19.6 and will be jointly performed by a Nevada State Fire Marshal licensed fire alarm contractor and an Elevator Service Company holding a valid C7 license. These tests must be witnessed by a Special Inspector/State Inspector.

Due to the current limited private sector resources available and for a limited time, until further notice by the division: A Special Inspector/State Inspector may accept a certificate of testing from a Nevada State Fire Marshal licensed fire alarm contractor and an Elevator Service Company holding a valid C7 license. The certificate must be signed by both as verification that testing has been successfully completed should the Special Inspector/Inspector not be available the day of the scheduled testing.

Reviewed and approved:


Randy Jewett, CAO
Mechanical Compliance Section
Division of Industrial Relations
Nevada Department of Business and Industry


Peter J. Mulvihill, P.E., Chief
State Fire Marshal Division
Nevada Department of Public Safety

*** witnessing of fire service testing may be documented on the Inspection Form or the Periodic Test Record: The name of the fire service company, the name of the fire service company technician and the technician's signature, elevator service company name, elevator service mechanic's name and the service mechanics signature must all be included to be acceptable.***

RJ