## NEVADA DEPARTMENT OF BUSINESS & INDUSTRY Division of Industrial Relations MECHANICAL COMPLIANCE SECTION



4600 Kietzke Lane, Suite F-151 Reno, Nevada 89502 Telephone: (775) 688-3750 Fax: (775) 688-1664 MCS.Reno@Business.nv.gov 1301 N. Green Valley ,Suite 200 Henderson, Nevada 89074 Telephone : (702) 486-9054 Fax: 702) 486-9176

MCS.Henderson@Business.nv.gov

Category 1 Hydraulic Elevator Periodic Test Record ASME A17.1 Sections 8.6.5.14 & 8.6.7												
Bui	Iding Name:	Address:					City, State, Zip:					
Building Hame.			Addices.									
Owners Name:			Address:			City, State, Zip:						
			_			-						
State Number:			Type:			Class:			T T	Use:		
NV			Freight: Passenger: Special Passenger:									
Running Speed: (Up) Running			g Speed: (Down) Levelii		eling Speed:							
1. ASME A17.1 Requirement 8.6.5.14.1: The relief valve setting shall be tested to determine that it will bypass the full output of the pu									numn			
before the pressure exceeds 150% of the working pressure and that the system will withstand this pressure.												
*** Calculations are not permitted in lieu of actual working pressure ***												
Was the valve adjusted and re-sealed? Yes No					Valve Sealed: Yes No							
Working Pressure:			psi Relief Valve Set								psi	
2. ASME A17.1 Requirement 8.6.5.14.2, (a) & (b): This test shall be performed after the relief valve setting and system pressure test in												
8.6.5.14.1. Cylinders and pressure piping that are exposed shall be visually examined. Cylinders and pressure piping that are not exposed												
shall be tested for leakage, which cannot be accounted for by the visual examination in 8.6.5.14.2(a) (Item 2.36.2). The duration of the test shall be for a minimum of 15 min (Item 2.36.2).												
	<u> </u>	Ob a										
Change in oil level in tank:  Elapse Time of Test:			inche	nge in car position ement of Car:	e in car position:			inches inches				
Test shows compliance with requirements:		minute:										
Test shows compliance with requirements: Yes No leading				1650	Test shows leakage:						No	
					Inspected: Yes No n/a					Date	<del>;</del> .	
3a 8.6.5.14.3(a) Normal Terminal Stopping Devices 3b 8.6.5.14.3(b) Governors, Overspeed Switch, and Seals					Yes			/a [ /a [	=			
3c	8.6.5.14.3(c) Safeties: (No Load		Yes			/a [ /a [	=					
3d	8.6.5.14.3(d) Oil Buffers: Car		Yes			/a [ /a [	_					
3e	` '		Yes			_	_					
8 6 5 14 3(e) Is the Report of Fire Testing received and signed by Nevada State Fire												
Marshal licensed Fire Alarm Contractor and Elevator Service Company w						S No	n,	/a [				
3f 8.6.5.14.3(f) Standby Power Operation (No Load)					Yes	s No	n.	/a [				
3g 8.6.5.14.3(g) Power Operations of Door System					Yes	Yes No n/a						
3h 8.6.5.14.3(h) Emergency Terminal Speed Limiting Devices					Yes	S No	n,	/a [				
3i 8.6.5.14.3(i) Low Oil Protection Operation					Yes			/a [				
4 8.6.5.14.4 Flexible Hose and Fitting Assemblies					Yes			/a [				
5 8.6.5.14.5 Pressure Switch					Yes		_	/a [				
8.6.5.14.6 Power Operation of Door System					Yes			/a [				
7	8.6.5.14.7 Slack Rope Device				Yes	S No	n,	/a [				
***	Test conforms to the Code in effect at time of original installation; a requirements at the time of any alteration; and ASME A17.3				Yes No (if no, explain)							
NOTES:												
NOTES.												
The Above Tests Were Performed In Compliance With ASME A17.1 and NAC 455C. 400-528 & Section 2 to 14												
Firm Performing Tests:					Date of Completion:							
	•											
Print Name, License No. & Signature of Person Performing Test				Prin	Print Name, License No. & Signature of Person Witnessing Test							

Report shall be filed with the Mechanical Compliance Section within ten (10) days of Performing Test
One copy to be retained by Authorized Inspection Agency