



Category 3 Periodic Test for Roped Water-Hydraulic Elevators & Pressure Vessels
ASME A17.1 Sections 8.6.5.15

Building Name:		Address:		City, State, Zip:	
Owners Name:		Address:		City, State, Zip:	
State Number:		Type:		Class:	
NV		Freight: <input type="checkbox"/> Passenger: <input type="checkbox"/>		Use:	
Running Speed: (Up)		Running Speed: (Down)		Leveling Speed:	
1. ASME A17.1, 8.6.5.15.1 Unexposed Portions of Pistons: Piston rods of roped water-hydraulic elevators shall be exposed, thoroughly cleaned, and examined for wear or corrosion. The piston rods shall be replaced if at any place the diameter is less than the root diameter of the threads (A17.2 - Item 5.11).					Date of Test:
Test conforms to the Code in effect at time of original installation; and requirements at the time of any alteration; and ASME A17.3					Yes <input type="checkbox"/> No <input type="checkbox"/> (If no, explain)
2. ASME A17.1, 8.6.5.15.2 Pressure Vessels. Pressure vessels shall be checked to determine conformance with the applicable requirements, thoroughly cleaned, internally examined and then subjected to a hydrostatic test at 150% of the working pressure for 1 min (3.24.4) (A17.2 - Item 2.33).					Date of Test:
Test conforms to the Code in effect at time of original installation; and requirements at the time of any alteration; and ASME A17.3					Yes <input type="checkbox"/> No <input type="checkbox"/> (If no, explain)

NOTES:

The Above Tests Were Performed In Compliance With ASME A17.1 and NAC 455C. 400-530	
Firm Performing Tests:	Date of Completion:
Print Name, License No. & Signature of Person Performing Test	Print Name, License No. & Signature of Person Witnessing Test

**Report shall be filed with the Mechanical Compliance Section within ten (10) days of Performing Test
 One copy to be retained by Authorized Inspection Agency**