NEVADA DEPARTMENT OF BUSINESS & INDUSTRY Division of Industrial Relations MECHANICAL COMPLIANCE SECTION



4600 Kietzke Lane, Suite F-151 Reno, Nevada 89502 Telephone: (775) 688-3750 Fax: (775) 688-1664 MCS.Reno@Business.nv.gov 1301 N. Green Valley ,Suite 200 Henderson, Nevada 89074 Telephone : (702) 486-9054 Fax: 702) 486-9176

MCS.Henderson@Business.nv.gov

Category 3 Periodic Test for Roped Water-Hydraulic Elevators & Pressure Vessels								
Building Name:		SME A17.1 Sections 8.6.5.15 Address:			City St	City, State, Zip:		
Building Name.		Audress.			Oity, Ott	City, State, Lip.		
Owners Name:		Address:			City, Sta	City, State, Zip:		
Ctata Number		T			Class			
State Number:		Type: Freight: Passenger:			Class: Use:		Use:	
Running Speed: (Up)	Running	Speed: (Down	_	Leveling Speed	<u> </u>			
Training operation (op)		<u> </u>	-,	g opeca	-			
1. ASME A17.1, 8.6.5.15.1 Unexposed Portions of Pistons: Piston rods of roped water-hydraulic elevators shall be exposed, thoroughly cleaned, and examined for wear or corrosion. The piston rods shall be replaced if at any place the diameter is less than the root diameter of the threads (A17.2 - Item 5.11).								
Test conforms to the Code in effect at time of original installation; and requirement alteration; and ASME A17.3				ements at the time of a	ents at the time of any Yes (If no, e			
2. ASME A17.1, 8.6.5.15.2 Pressure Vessels. Pressure vessels shall be checked to determine conformance with the applicable requirements, thoroughly cleaned, internally examined and then subjected to a hydrostatic test at 150% of the working pressure for 1 min (3.24.4) (A17.2 - Item 2.33).								
Test conforms to the Code in effect at time of original installation; and alteration; and ASME A17.3			quire	uirements at the time of any		Yes ☐ No ☐ (If no, explain)		
NOTES:							·	
_								
The Above Tests Were Performed In Compliance With ASME A17.1 and NAC 455C. 400-528 & Section 2 to 14								
Firm Performing Tests:				Date of Completion	:			
Print Name, License No. & Signature of Person Performing Test				Print Name, License No. & Signature of Person Witnessing Test				

Report shall be filed with the Mechanical Compliance Section within ten (10) days of Performing Test
One copy to be retained by Authorized Inspection Agency